



**Results Report**

Order ID: 7082318

Karl Environmental Group  
20 Lauck Road  
Mohnton, PA 19540

Project: Northern Valley Regional SD - Demarest HS  
150 Knickerbocker Road  
Demarest, NJ 07627

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7082318-01	Site: NVD-BLANK-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:40 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:34	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-02	Site: NVD-FP-1FL-KITCH-3-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:44 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.43	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:36	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-03	Site: NVD-TL-1FL-FACCAF-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:48 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.05	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:38	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-04	Site: NVD-HB-1FL-G107EXT-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 7:01 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	16.4	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:40	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-05	Site: NVD-FP-1FL-B101-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 7:05 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.52	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:46	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 08/17/2017 3:58 pm 7082318  
STL\_Results Revision #1.6 Effective: 07/09/2014





**Results Report**

Order ID: 7082317

Karl Environmental Group  
20 Lauck Road  
Mohnton, PA 19540

Project: Northern Valley Regional SD - Demarest-Reno  
150 Knickerbocker Road  
Demarest, NJ 07627

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7082317-01  
Collector: KM

Site: NVD2-BLANK-PR  
Collect Date: 08/08/2017 7:13 am

Sample ID:  
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/08/17 RPV 08/16/17 3:17 RPV

Sample Number: 7082317-02  
Collector: KM

Site: NVD2-WC-1FL-BOYSLOCK-1-PR  
Collect Date: 08/08/2017 7:14 am

Sample ID:  
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/08/17 RPV 08/16/17 3:23 RPV

Sample Number: 7082317-03  
Collector: KM

Site: NVD2-WC-1FL-BOYSLOCK-2-PR  
Collect Date: 08/08/2017 7:15 am

Sample ID:  
Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 08/08/17 RPV 08/16/17 3:29 RPV

Sample Number: 7082317-04  
Collector:

Site: Laboratory Control Sample  
Collect Date: 08/08/2017 12:00 am

Sample ID:  
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.6 µg/L EPA 200.8 1.00 1 08/08/17 RPV 08/16/17 3:30 RPV

Sample Number: 7082317-05  
Collector:

Site: Laboratory Control Sample Duplicate  
Collect Date: 08/08/2017 12:00 am

Sample ID:  
Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.5 µg/L EPA 200.8 1.00 1 08/08/17 RPV 08/16/17 3:32 RPV

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 08/17/2017 3:55 pm 7082317  
STL\_Results Revision #1.6 Effective: 07/09/2014





# SUBURBAN TESTING LABS

NVD

Sample Number: 7082318-06	Site: NVD-FP-1FL0-105-7-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 7:10 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	9.56	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:48	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-07	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 08/08/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	12.7	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:52	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082318-08	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 08/08/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.4	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:54	RPV
------	------	------	-----------	------	---	----------	-----	---------------	-----

### Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

### Reviewed and Released By:

Alana Kopicz  
Project Manager

Report Generated On: 08/17/2017 3:58 pm 7082318  
STL\_Results Revision #1.6 Effective: 07/09/2014





**Results Report**

Order ID: 7082320

Karl Environmental Group 20 Lauck Road Mohnton, PA 19540  Attn: Kelly Mays	Project: Northern Valley Regional SD - Old Tappan HS 140 Central Ave Old Tappan, NJ 07675  Regulatory ID:
--	---

Sample Number: 7082320-01	Site: NVO-BLANK-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:00 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:56	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082320-02	Site: NVO-WC-1FL-HALLB105-1-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:02 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 3:58	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082320-03	Site: NVO-WC-1FL-HALLB105-2-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:03 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 4:00	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082320-04	Site: NVO-WC-2FL-HALLB207-1-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:05 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 4:02	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Sample Number: 7082320-05	Site: NVO-WC-2FL-HALLB207-2-PR	Sample ID:
Collector: KM	Collect Date: 08/08/2017 6:07 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	08/08/17	RPV	08/16/17 4:04	RPV
------	--------	------	-----------	------	---	----------	-----	---------------	-----

Report Generated On: 08/17/2017 3:57 pm      7082320  
 STL\_Results Revision #1.6      Effective: 07/09/2014

